



24 Brisbane Street, Sydenham, Christchurch 8023
Phone (03) 377 7599, Fax (03) 377 9393, www.ges.co.nz

Gas Appliance Endorsement Certificate of Compliance

This certificate is pursuant to Regulations 57 of the Gas (Safety and Measurement) Regulations 2010 (as amended). The appliance scheduled within has been tested to comply with the requirements of the regulations and NZS 5266

CLIENT	BRANZ	INSTALLATION	BRANZ testing laboratory
ADDRESS	1222 Moonshine Road, Judgeford 5381	ADDRESS	1222 Moonshine Road, Judgeford 5381

Appliance Details


APPLIANCE MAKE	BTL Furnaces	APPLIANCE MODEL	F2 – 5.28MW Combi Furnace 3/3/4, RWS	APPLIANCE TYPE	Horizontal test furnace
GAS TYPE	LPG	APPLIANCE TESTING STANDARD	AS 3814	TEST DATE	06 March 2025
MARKINGS AND INSTRUCTION	Pass	MATERIALS / CONSTRUCTION	Pass	SURFACE TEMPERATURE	Pass
WORKING PRESSURE (KPA)	95mBar	MAX PRESSURE (KPA)	100mBar	MINIMUM PRESSURE (KPA)	90mBar
FLAME SAFEGUARDS	UV - pass	IGNITION TYPE	Electronic - Pass	BURNER TYPE	Eclipse TJ200 Nozzle mix
COMBUSTION AIR SUPPLY	Induced - pass	COMBUSTION AIR CONTROLS	Servo damper - pass	MODULATION CONTROL	Pass

Test Results

GAS VALVE TRAIN	Pass	IGNITION SEQUENCE	Pass	PILOT TYPE	Low fire - pass
LP GAS SWITCH	Pass	HP GAS SWITCH	Pass	AIRFLOW INTERLOKS	Pass
PURGE SEQUENCE	Pass	AIR CHANGES	X 12	LEAKAGE DETECTION	Pass
PILOT BURNER IGNITION	Low fire - Pass	PILOT STABILITY	Low fire - Pass	COMBUSTION TEST	Pass
MAIN BURNER IGNITION	Pass	MAIN BURNER STABILITY	Pass	COMBUSTION TEST	Pass
FLAME SUPERVISION TEST	Pass	LEAKAGE TEST	Pass	RE-IGNITION TEST	Pass

"I believe on reasonable grounds that:

- (a) the gas appliance testing as described above has been done lawfully and safely; and
- (b) the appliance has been tested to comply with regulation 57 of the Gas Safety and Measurements Regulations 2010
- (c) the work done [x] has [] has not (tick one) relied on any manufacturers instructions; and
- (d) The gas appliance is safe to use; and
- (g) the information contained in this certificate is correct.

INSTALLERS	Marshall Weenink 16489		
CERTIFIER NAME	Marshall Weenink		
REGISTRATION N°	16489		
SIGNATURE			
DATE	03 June 2025		

