

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CM0128

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Distributor <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	LUNA DUO-TEC MP+...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: 18/112/3204/033 from 03.04.2018 (EBI) supplement test: 18/166/3204/033 from 25.06.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	18-0484-GWA

18.07.2018 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkennzeichnung</i>
LUNA DUO-TEC MP+ 1.35	nominal heat output: 5,0...33,8 kW heat input (Hi): 5,1...34,8 kW	
LUNA DUO-TEC MP+ 1.50	nominal heat output: 5,0...45,0 kW heat input (Hi): 5,1...46,3 kW	
LUNA DUO-TEC MP+ 1.60	nominal heat output: 6,1...55,0 kW heat input (Hi): 6,3...56,6 kW	
LUNA DUO-TEC MP+ 1.70	nominal heat output: 7,2...65,0 kW heat input (Hi): 7,4...66,9 kW	
LUNA DUO-TEC MP+ 1.90	nominal heat output: 9,4...85,0 (natural gas); 12,2...85,0 (LPG) kW heat input - natural gas (Hi): 9,7...87,4 kW heat input - LPG (Hi): 12,5...87,4 kW	
LUNA DUO-TEC MP+ 1.110	nominal heat output: 11,4...102,0 kW heat input (Hi): 11,7...104,9 kW	
LUNA DUO-TEC MP+ 1.115	nominal heat output: 24,3...112,8 (natural gas); 34,7...112,8 (LPG) kW heat input (Hi): 24,8...115,0 (natural gas); 35,4...115,0 (LPG) kW	
LUNA DUO-TEC MP+ 1.130	nominal heat output: 24,3...121,5 (natural gas); 34,7...121,5 (LPG) kW heat input (Hi): 24,8...123,8 (natural gas); 35,4...123,8 (LPG) kW	
LUNA DUO-TEC MP+ 1.150	nominal heat output: 28,1...140,3 (natural gas); 40,0...140,3 (LPG) kW heat input (Hi): 28,6...143,0 (natural gas); 40,9...143,0 (LPG) kW	

SUPPLIER DECLARATION OF CONFORMITY (SDoC)

In accordance with ISO/IEC 17050-1:2004

SDoC Identification Number¹: CHNZDUOMP

Issuer details

Name² (of New Zealand manufacturer or importer):

Central Heating New Zealand

Telephone:

03 357 1233

New Zealand Company No. (if applicable):

1189437

Email Address:

info@centralheating.co.nz

Contact Address:

Central Heating New Zealand
52 Pilkington Way
Wigram
Christchurch 8042

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

Duo-tec MP+ Range – including 1.35,1.50,1.70,1.90,1.110,1.130,1.150

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴:

Standard number and issue year:

EU/2016/426

Standard number and issue year:

Edition / Amendment status:

A III B

Edition / Amendment status:

Standard title:

Standard title:

AS/NZS ZZ modified

Yes ☐

No ☐

N/A ☐

AS/NZS ZZ modified

Yes ☐

No ☐

N/A ☐

OR Complies with the Conformity Cooperation Agreement (CCA)⁵

Yes ☐

No ☐

OR is registered on the EESS database & the declarer is registered as the responsible/affiliated supplier⁶ Yes ☐ No ☐ EESS Equipment # _____

Names and addresses of any Evaluating/Testing/Certification organisation or body used

Name(s):

DVGW

Address(es):

Name(s):

Address(es):

Reference to relevant test reports/certification and the issue date that show how compliance is achieved

Supporting document(s) used, to show how compliance with the declared standard(s) is achieved or CCA certification:

Supplier Test Certification

Report Certification or Document reference N°(s):

CE-0085CM0128

Issue dates(s):

18.07.2018

Reference to any management quality system involved:

Additional information⁷:

Declaration (signed for and on behalf of):-

Name and position as authorised by the issuer⁸:

Nicola Barry, Operations Manager

Issuer Identification (as affixed to the article):

Signature:



Date:

Dec 2020